

Translations:Filtre bio-sable pour eau potable/48/en

- Repeat filling everyday so that biological layers oxygenates and has pathogens to eat. Respect a 1h minimum and 48h maximum delay between two fillings. Below 1h, the filter will not act properly and above 48h, the biological layer degradates.