

Translations: Remorque génératrice solaire - Système électrique/73/en

- Overcurrent protective devices ("fuses or circuit breakers") must be installed to protect the equipment from high current conditions:
 - At the SP output, on the two polarities (+ and -), against the risks of overcurrent under the forme of courant retour. Not necessary, if you have only one channel of SP in series.
 - At the battery output, on the +, against the high discharge currents.