

Translations: Remorque génératrice solaire - Système électrique/93/en

From these calculated sections, it is then necessary to choose the upper commercial section:

| Between the SP and the charge regulator | Between the charge regulator and the batteries | Between the batteries and the inverter |
|---|--|--|
| S = 2,5mm ² | S= 10mm ² | S=10 ou 16 mm ² |

We can verify the maximum allowable intensity values corresponding to these sections in the counting frame (see image).